



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

# **SKILL SHEET PACKAGE**

Based on NFPA 1001: Standard for  
Fire Fighter I Professional Qualifications, 2013 Edition

June 2016



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 1-A**

**Personal Protective Equipment**

**PERFORMANCE STANDARD**

Don personal protective clothing within one (1) minute: doff personal protective clothing and prepare for reuse

**INSTRUCTIONS**

At this station, you will be required to don personal protective clothing within one (1) minute. The exact sequence of donning the clothing is not graded. However, once completed, all components must be correctly worn and ready for fire fighting operations. When you have completed all donning procedures, clap your hands and I will stop your time.

**PREPARATION & EQUIPMENT**

Bunker pants  
Coat  
Hood  
Gloves  
Helmet  
Stopwatch



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 1-A</b>	<b>Scored points</b>		<b>Scored points</b>	
<b>Donning</b>				
Trouser legs over boots..... 1pts				
Hood on properly (no exposed hair).....2pts				
Coat completely fastened..... 1pts				
Coat collar up and fastened..... 1pts				
Helmet secured under chin..... 2pts				
All articles of protective clothing donned within 1 minute..... P/F				
<b>Doffing</b>				
Gloves in coat pocket..... 1pts				
Helmet stored with front facing back of storage unit..... 1pts				
Hood in coat pocket..... 1pts				
Coat on storage hook with collar up & front completely unfastened..... 1pts				
Boots and trousers doffed as one..... 1pts				
Boot/Trouser combination stored with suspenders to each side and boot toes facing back of storage unit..... 1pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 10 out of 13 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 1-B**

**Rope, Knots, Tool Hoisting**

**PERFORMANCE STANDARD**

Hoist a tool and/or piece of equipment using the correct knot(s)

**INSTRUCTIONS**

At this station, you will be required prepare tools and equipment to be hoisted to the roof of a building. You may use any fire service knots of your choice that are appropriate to the tool or equipment to be hoisted. You must back up each knot with a safety knot as appropriate. After you have prepared all the tools and equipment, I ask you to tie knots that you have not previously demonstrated. You may remove your gloves for this station.

**PREPARATION & EQUIPMENT**

Utility rope  
Forcible entry tools  
Pike pole  
Ground ladder  
Roof ladder  
Hose line  
Full protective equipment



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.20	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 1B</b>	Scored points	Scored points
Tie a fire department approved knot(s) for the tools or equipment selected (i.e. bowline, figure eight on a bite, clove hitch, half hitch, and becket or sheet bend).....1pts		
Utilize a safety knot for additional support.....2pts		
Hoist or have hoisted a tool and/or piece of equipment to a designated height.....P/F		
Untie the knot(s) without difficulty.....1pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 3 out of 4 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 1-C**

**Response Information Guidelines**

**PERFORMANCE STANDARD**

Locate information in departmental documents and standard or code materials

**INSTRUCTIONS**

At this station, you will be able to demonstrate the ability to locate written documents, policies, procedures, and standard or code materials

**PREPARATION & EQUIPMENT**

Department Standard Operating Procedures  
NFPA Standard or Code Book



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 1C</b>	<b>Scored points</b>		<b>Scored points</b>	
Locate a department standard operating procedure <i>(CO may opt for SOP/SOG related to a selected skill                      station within final exam packet).....2pts</i>				
Locate a NFPA standard or code <i>(specific standard or                      code determined by Certifying Officer).....2pts</i>				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 3 out of 4 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_





**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 2**

**Initiate Emergency Response**

**PERFORMANCE STANDARD**

Initiate a response to a reported emergency, so that all necessary information is obtained, communications equipment is operated correctly, and the information is relayed promptly and accurately to the dispatch center

**INSTRUCTIONS**

At this station, you will receive a call from a citizen that will initiate an emergency response or will deal with a routine matter. Appropriate deal with the caller, operate the communications gear, and relay the information in an appropriate manner.

**PREPARATION & EQUIPMENT**

Department SOP/SOG  
Communication equipment  
Paper  
Pencil



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.2.1	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 2</b>	Scored points		Scored points	
Verbalize how the alarm is received.....1pts				
Write proper address and nature of the emergency.....1pts				
Promptly contacts dispatch by radio indicating an alarm has been received.....1pts				
Notify dispatch that a response to the emergency has been Initiated.....1pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 3 out of 4 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 3**

**Phone Operations**

**PERFORMANCE STANDARD**

Given a fire department phone, receive a telephone call, so that procedures for answering the phone are used and the caller's information is relayed

**INSTRUCTIONS**

At this station you will be able to operate fire station telephone and required to record the information.

**PREPARATION & EQUIPMENT**

Telephone  
Paper  
Pencil



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.2.2	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 3</b>	<b>Scored points</b>	<b>Scored points</b>
Answer the call promptly.....1pts		
Identify himself/herself and the department to the caller.....1pts		
Ensure paper and pencils (or pen) are available .....1pts		
Take an appropriate message (e.g.: date, time, caller, caller's phone number and person taking call).....1pts		
End the call courteously and in a timely manner		
Deliver a message or transfer the call to the appropriate person.....1pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 4 out of 5 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 4**

**Radio Operations**

**PERFORMANCE STANDARD**

Transmit and receive messages via the fire department radio, so that the information is accurate, complete, clear, and relayed within the time established by fire department policy and procedure

**INSTRUCTIONS**

At this station, you will be required to operate a fire department radio to receive and transmit both routine and emergency traffic. You will be required to discriminate between routine and emergency traffic and act appropriately.

**PREPARATION & EQUIPMENT**

Fire department mobile or portable radio  
Interior structure props (simulating lost/trapped, stuck, falling through a floor, or collapsed on),  
Full protective clothing  
SCBA (on air)



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 4</b>	<b>Scored points</b>	<b>Scored points</b>
Determine there is no other radio traffic before transmitting (unless emergency traffic).....1pts		
Have microphone within 1-2 inches of mouth (or speaking device of SCBA).....1pts		
Speak calmly, clearly, distinctly and at a medium speed..... 1pts		
Transmit a message that is brief, accurate and to the point.....1pts		
Identify who the message is addressed to.....1pts		
Identify the person or unit transmitting.....1pts		
Provides correct information during emergent situation (i.e. firefighter mayday).....1pts		
Acknowledges information back from command (if applicable).....1pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 6 out of 8 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 5-A**

**Don/Doff Self Contained Breathing Apparatus**

**PERFORMANCE STANDARD**

Use SCBA during emergency operations, so that the SCBA is correctly donned and activated within 1 minute, and SCBA is correctly worn

**INSTRUCTIONS**

At this station, you will be required to don Self-Contained Breathing Apparatus (SCBA) within one (1) minute. The method and exact sequence of donning the SCBA is not graded. When you have completed all donning procedures, clap your hands and I will stop your time. Once you have clapped your hands indicating you are done, do not touch your gear until I have checked it. You will start this station wearing your helmet (with loosened chinstrap) but not your gloves. However, once completed, the SCBA must be correctly worn and you should be ready for interior fire fighting operations.

**PREPARATION & EQUIPMENT**

Complete SCBA ensemble  
Full bunker gear  
Stopwatch



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.1	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 5A</b>	<b>Scored points</b>		<b>Scored points</b>	
Verify that the SCBA is ready for service and confirm the amount of air in the cylinder is above minimum acceptable level.....1pts				
Correctly don SCBA backpack assembly.....1pts				
Open SCBA cylinder valve.....1pts				
Check gauge for operation and verify air cylinder pressure.....1pts				
Verify activation and operation of pass device.....1pts				
Correctly don face piece .....2pts				
Check face piece seal and operation of exhalation valve.....1pts				
Connect face piece to air supply/regulator.....1pts				
Have all personal protective clothing correctly in place.....1pts				
Correctly accomplished above steps within one (1) minute.....1pts				
Remove SCBA and place all equipment in a ready state for reuse.....1pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 9 out of 12 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_





**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 5-B**

**Use Self Contained Breathing Apparatus- Controlled Breathing**

**PERFORMANCE STANDARD**

Use SCBA during emergency operations, so that the SCBA is correctly worn, controlled breathing techniques are used, emergency procedures are enacted if the SCBA fails, all low-air warnings are recognized, respiratory protection is not intentionally compromised

**INSTRUCTIONS**

This station has three parts which must be completed on a single tank of air. You will be required to demonstrate your ability to control your breathing while wearing SCBA. You will demonstrate SCBA emergency procedures. Remember that the station must be completed on a single tank of air.

**PREPARATION & EQUIPMENT**

Complete SCBA ensemble  
Full bunker gear



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.1	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 5B</b>	<b>Scored points</b>	<b>Scored points</b>
Recognize and acknowledge all low air warning alarms.....2pts		
<b>CONSERVATION OF AIR</b>		
Demonstrate controlled breathing: (e.g., Inhale through the nose, exhale through the mouth, and control rate of breathing).....2pts		
Demonstrate skip breathing: (e.g., take a regular breath and hold, take another breath, exhale, and repeat).....2pts		
<b>SCBA FAILURE: Air Delivery System</b>		
Check regulator/open bypass.....1pts		
Check that the low pressure line between regulator and pressure reducer is intact.....1pts		
Check cylinder valve making certain it is fully open.....1pts		
<b>Regulator Failure</b>		
Close mainline if present.....1pts		
Open by-pass slowly.....1pts		
Close by-pass after each breath.....1pts		
Open bypass for next breath.....1pts		
<b>DEPLETION OF AIR SUPPLY: Out of air with no air resupply available</b>		
Activate pass device.....1pts		
Establish filter breathing (if compatible with SCBA design) while staying as low as possible.....1pts		
Exit hazardous area rapidly.....2pts		
<b>Out of Air – Emergency Breathing Safety System Available (if present on SCBA)</b>		



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Attach Emergency Breathing Safety System hose to SCBA unit needing assistance.....1pts			
Exit hazardous area prior to air depletion.....2pts			
<b>Out of air with full cylinder available (non-hazardous atmosphere)</b>			
Doff backpack (skip if changing cylinder on a team member).....2pts			
Close cylinder valve and release pressure.....1pts			
Disconnect hose/pack assembly from cylinder.....1pts			
Remove depleted cylinder.....1pts			
Replace with cylinder containing air.....1pts			
Connect hose/pack assembly to cylinder.....2pts			
Turn on cylinder and check regulator pressure .....1pts			
Re-don backpack (skip if changing cylinder on a team member).....2pts			
<b>Total Score</b>			
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass <input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 25 out of 31 points for passing.

**Proctor Comments:**

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 5-C**

**Use Self Contained Breathing Apparatus- Restricted Passage**

**PERFORMANCE STANDARD**

Given SCBA and other personal protective equipment, use SCBA during emergency operations, so that the SCBA is correctly worn, emergency procedures are enacted if the SCBA fails, all low-air warnings are recognized, respiratory protection is not intentionally compromised, and hazardous areas are exited prior to air depletion

**INSTRUCTIONS**

This station has three parts which must be completed on a single tank of air. You will exit through a restricted passage while wearing SCBA. When exiting through the restricted space, you are to do so without completely removing your SCBA backpack assembly if possible. You will demonstrate SCBA emergency procedures. Remember that the station must be completed on a single tank of air.

**PREPARATION & EQUIPMENT**

Complete SCBA ensemble  
Full bunker gear  
Prop for restricted opening



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.3.1	<u>TEST</u>	<u>RETEST</u>
Performance Test # 5-C	Scored points	Scored points
<b>Remove the Backpack Method</b>		
Remove SCBA backpack, not compromising face-piece seal or ability to breathe.....2pts		
Push backpack through opening, not compromising SCBA operation.....1pts		
Enter opening and proceed through opening completely.....2pts		
Redon SCBA backpack assembly.....1pts		
Ensure that mask seal or SCBA functioning was not compromised during maneuver.....1pts		
Exit hazardous area prior to air depletion.....2pts		
<b>Reduce Profile Method</b>		
Loosen straps as necessary to reduce profile by sliding tank to side .....1pts		
Reduce profile further by removing one or both backpack harness straps (ONLY if necessary to maneuver through passage)..... 1pts		
Enter opening and proceed through opening completely.....2pts		
Redon/Secure SCBA backpack assembly to body.....1pts		
Ensure that mask seal or SCBA functioning was not compromised during maneuver.....1pts		
Exit hazardous area prior to air depletion.....2pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 14 out of 17 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



# Arab Fire Safety and Security Academy (AFSSAC)

## FIRE FIGHTER I

### PERFORMANCE STANDARDS

#### NFPA 1001, 2013 Edition

---

### Performance Test # 6

### Apparatus Response

#### PERFORMANCE STANDARD

Respond on an apparatus to an emergency scene, so that the apparatus is correctly mounted and dismounted, seat belts are used while the vehicle is in motion, and other personal protective equipment is correctly used

#### INSTRUCTIONS

At this station, you will be required to safely mount this apparatus, assume a seated position in the rear portion of the cab, and prepare to depart, simulating an emergency response as a member of the apparatus' crew. When you are completely prepared to depart the station on the simulated emergency run, tell me so that I may check you. Once I have completed checking you, you will be required to safely dismount the apparatus as if you had arrived on-scene

#### PREPARATION & EQUIPMENT

Fire apparatus

Personal protective equipment

Hearing protection

Eye protection (*for those not in enclosed cabs*)

SCBA's for departments/organizations that allow or require firefighters to don SCBA's while in route to the emergency.



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.2	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 6</b>	<b>Scored points</b>		<b>Scored points</b>	
<b>MOUNTING</b>				
Properly don personal protective clothing.....2pts				
State that the vehicle is not in motion.....P/F				
Mount fire apparatus using handrails.....2pts				
Close door, safety bar, gate to cab or compartment.....1pts				
Sit and fasten seat belt .....P/F				
Correctly use any other personal protective equipment furnished.....1pts				
<b>DISMOUNTING</b>				
Wait for order(s) before leaving apparatus.....1pts				
State that vehicle is completely stopped before leaving apparatus.....P/F				
Look for hazards before stepping off vehicle.....1pts				
Safely step from vehicle using handrails.....2pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 8 out of 10 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 7**

**Emergency Scene Operations**

**PERFORMANCE STANDARD**

Establish and operate in work areas at emergency scenes, structure fire and roadway emergency scenes, traffic hazards and downed electrical wires, so that procedures are followed, protective equipment is worn, protected work areas are established, and the candidate performs assigned tasks only in established, protected work areas

**INSTRUCTIONS**

At this station, you will be required to respond on this apparatus as a member of its crew to the simulated scene of a motor vehicle accident. Upon arrival, you will dismount the apparatus and set out traffic control devices to establish a safe work area in which to conduct vehicle extrication operations, and then prepare to participate in those operations.

**PREPARATION & EQUIPMENT**

Fire apparatus  
Personal protective equipment  
Traffic control devices





**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.3	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 7</b>	<b>Scored points</b>	<b>Scored points</b>
Survey emergency scene for hazards according to department SOP's... 1pts		
Identify potential for injury based on identified hazards..... 1pts		
Verbalize a plan for mitigation of hazards.....P/F		
Properly dismounts apparatus with PPE correctly worn.....2pts		
Using traffic cones, and verbalizing the placement of apparatus, establish a safe work area..... 1pts		
Verbalize how structure, roadway emergency scenes, traffic hazards, and downed power lines would be treated and isolated.....P/F		
Verbalize dynamic nature of scene safety ( <i>other potential hazards</i> )....P/F		
Describe measures to ensure continued scene safety..... 1pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 5 out of 6 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 8**

**Forcible Entry**

**PERFORMANCE STANDARD**

Force entry into a structure, so that the tools are used as designed, the barrier is removed, and the opening is in a safe condition and ready for entry

**INSTRUCTIONS**

At this station, you will be required force entry into a building, through a door, a window, or a wall. I will give you your specific assignment shortly. You must observe all safety precautions and demonstrate proper use of tools, ensuring that the opening is in a safe condition and ready for entry when you indicate to me that you are done. Do not skip steps or assume anything about the door, window or wall.

**PREPARATION & EQUIPMENT**

Personal protective equipment  
Appropriate hand tools or power tools  
Forcible entry prop for a door  
Window  
Wall breach (if available)



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.4	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test #8</b>	<b>Scored points</b>	<b>Scored points</b>
<b>DOOR</b>		
Select the correct tool(s).....1 pts		
Safely carry the selected tool(s) to the door .....2 pts		
Try the door to verify it is locked before forcing .....1 pts		
Correctly size up the door .....1 pts		
Choose an appropriate technique and demonstrate or simulate forced entry...1 pts		
Use hand and eye protection.....2 pts		
Clear opening all of obstacles .....2 pts		
<b>WINDOW</b>		
Select the correct tool(s) .....1 pts		
Safely carry the selected tool(s) to the window .....2 pts		
Try the window to verify it is locked before forcing .....1 pts		
Correctly size up the window .....1 pts		
Choose an appropriate technique and demonstrate or simulate forced entry ...1 pts		
Use hand and eye protection.....2 pts		
Clear opening all of obstacles .....2 pts		
<b>WALL</b>		
Correctly size up the wall to be breached.....1 pts		
Identify common breaching hazards.....2 pts		
Select the correct tool(s) for the type of wall.....2 pts		
Sound for studs ( <i>if appropriate</i> ) and choose an appropriate technique and demonstrate or simulate forced entry .....1 pts		
Use hand and eye protection .....2 pts		
Make an appropriate sized opening .....1 pts		
Clear the opening of obstacles .....2 pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Required to pass:**

Candidate must receive a mandatory score of 26 out of 31 points for passing.

**Proctor Comments:**

---

---

---

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 9**

**Exit Hazardous Environment**

**PERFORMANCE STANDARD**

Exit a hazardous area as a member of a team, so that a safe haven is found before exhausting the air supply, others are not endangered, and the team integrity is maintained

**INSTRUCTIONS**

At this station, we will simulate that you have been conducting a search of a smoke-filled, burning building and the Incident Commander has ordered all personnel out of the building. You will be required to operate as part of a team, locate your (search line) (fire hose), and make your way out. As you make your way out, you will be required to communicate with you team mate(s) any hazard(s) you encounter as well as any possible safe haven(s) you locate in the event you cannot reach safety. I will lead you to your starting location at which point you will go on air. I will act as the Incident Commander and send you a simulated radio message ordering you out of the building, at which point you will begin.

**PREPARATION & EQUIPMENT**

Personal protective equipment  
SCBA (on air)  
Hand tools  
Obscured vision  
Hose line/guideline



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.5	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 9</b>	<b>Scored points</b>		<b>Scored points</b>	
Determine air supply available when entering hazardous atmosphere...2pts				
Monitor the air supply available while in hazardous atmosphere.....2pts				
Identify the need to leave hazardous atmosphere before depletion of air supply while maintaining team integrity..... 1pts				
Communicate need for egress with team member(s) ..... 2 pts				
Locate hose line or guideline and determine correct method of travel for egress..... 1 pts				
Follow hose line or guideline towards exit with all team members.....1 pts				
Exit hazardous atmosphere with all team members before depletion of air supply ..... 1 pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 8 out of 10 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 10**

**Ground Ladders**

**PERFORMANCE STANDARD**

Set up ground ladders, so that hazards are assessed, the ladder is stable, the angle is correct for climbing, extension ladders are extended to the necessary height with the fly locked, the top is placed against a reliable structural component, and the assignment is accomplished

**INSTRUCTIONS**

At this station, you will operate (individually) (as a member of a team), demonstrating the ability to carry ladders; set and raise ladders; judge correct angle for climbing; and judge extension ladder height requirements. You will be required to assess overhead hazards, strength of structural support components, and any other existing hazards. You must verbalize decisions you make in your head. You will carry the ladders from the start point to a location appropriate to the scenario I give you. The scenarios will tell you whether you are conducting a rescue from a window, laddering a roof, etc. You are required to observe all safety precautions when moving ladders. You may use an approved ladder carry technique of your choice. You may use any approved method of raising the ladder appropriate to the scenario I give you and the location of the raise. At the end of this scenario, you will safely lower the ladder and return it to the start point.

**PREPARATION & EQUIPMENT**

24' or 35' extension ladder  
Full personal protective clothing  
SCBA



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.6	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 10</b>	<b>Scored points</b>	<b>Scored points</b>
<b>DEPLOY, RAISE, AND EXTEND LADDER</b>		
Select the proper length ladder for the designated task .....P/F		
Coordinate with team member to correctly lift/carry the ladder from the designated area or apparatus to the area of deployment .....2 pts		
Visually check work area for hazards and state if area is safe or if hazards exist .....1 pts		
Determine ladder placement and verify that the wall/roof will support ladder .....P/F		
Raise the ladder (beam or flat) and ensure proper fly orientation .....1 pts		
Extend fly section to proper height and ensure fly is locked (if using an extension ladder) .....1 pts		
Lower ladder against stable wall or surface and secure halyard .....1 pts		
Adjust ladder for proper climbing angle and ensure placement for given task .....2pts		
Position ladder correctly for task given .....2 pts		
<b>RETRACT, LOWER, AND RETURN LADDER</b>		
Move top of ladder away from building, release halyard, locks, and correctly lower fly(s) ....1 pts		
Lower ladder to ground (reversing raising procedures).....1 pts		
Coordinate with team member to lift/carry the ladder from the deployment area to the designated area or apparatus ..... 2pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 11 out of 14 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_





**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 11**

**Vehicle Fire Attack**

**PERFORMANCE STANDARD**

Attack a passenger vehicle fire while operating as a member of a team, so that hazards are avoided, leaking flammable liquids are identified and controlled, protection from flash fires is maintained, all vehicle compartments are overhauled, and the fire is extinguished

**INSTRUCTIONS**

At this station, you will be required to extinguish or control a passenger vehicle live fire as a member of a team. You will use appropriate protective equipment, fire fighting tools, and extinguishing agents. You will be required to assess all hazards; utilize safety precautions; identify and control all fuel leaks; expose hidden fires; provide protection for team members from flash fire while advancing an attack line; applying water with maximum effectiveness; and extinguishing the fire.

**PREPARATION & EQUIPMENT**

Hose lines  
Fire apparatus  
Personal protective equipment  
SCBA (on air)  
Hand tools  
Automobile  
Light truck or van  
Dedicated safety line personnel



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.7 <b>Performance Test # 11</b>	<b>TEST</b>		<b>RETEST</b>	
	<b>Scored points</b>		<b>Scored points</b>	
Properly wear full protective clothing and SCBA (on air) .....P/F				
Select at least 1 ½ inch hose line, bleed line, and adjust nozzle .....1 pts				
Attack from upwind and uphill (verbalize conditions were considered if not applicable).....1 pts				
Protect exposures (if present) .....1 pts				
Approach vehicle from side or 45 degree angle (never in front of bumpers until cooled) adjusting nozzle flow and stream for team protection ....2 pts				
Identify possible fuel types and methods for controlling fuel leaks ....1 pts				
Extinguish ground fire around and under the vehicle .....1 pts				
Expose all hidden fire and open all compartments using appropriate techniques and extinguish remaining fires within the vehicle.....1 pts				
Overhaul the fire scene and preserve evidence if indicated .....1 pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 7 out of 9 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 12**

**Exterior Fire Attack**

**PERFORMANCE STANDARD**

Extinguish a fire in exterior Class A materials, so that exposures are protected, the spread of fire is stopped, collapse hazards are avoided, water application is effective, the fire is extinguished, and signs of the origin area(s) and arson are preserved

**INSTRUCTIONS**

At this station, working as a member of a team, you will extinguish (an exterior dumpster fire) (a trash bin fire) (a burning stack or pile of Class A material). You will be required to wear full personal protective clothing ensemble with SCBA, use fire fighting hand tools, and an attack line. You must approach the fire correctly and then perform necessary overhaul and extinguishment procedures. You should indicate to me any hazards associated with the particular type of fire.

**PREPARATION & EQUIPMENT**

Stack of Class A material or unattached structure or storage container  
Hose lines (min. 1 ½ inch)  
Hand tools  
Dedicated safety line with personnel  
Fire/pumper apparatus  
Full personal protective equipment with SCBA (on air)



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.8	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 12</b>	<b>Scored points</b>	<b>Scored points</b>
Describe inherent hazards related to burning material configuration ....1 pts		
Select and deploy the appropriate size hose line .....1 pts		
Attack from upwind and uphill or flanks (verbalize if not applicable)...2 pts		
Bleed air from hose line and adjust nozzle for maximum effectiveness...1 pts		
Protect exposures (if present) .....1 pts		
Break-up burning material using hand tools and water streams .....1 pts		
Search for and expose hidden fires .....1 pts		
Extinguish the fire .....1 pts		
Overhaul fire scene while protecting and preserving signs of cause or origin if present .....1 pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 8 out of 10 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 13**

**Interior Search and Rescue**

**PERFORMANCE STANDARD**

Conduct a search and rescue in a structure operating as a member of a team, so that ladders are correctly placed when used, all assigned areas are searched, all victims are located and removed, team integrity is maintained, and team member's safety – including respiratory protection – is not compromised

**INSTRUCTIONS**

At this station, you will be required to demonstrate skills for conducting a search and rescue in a vision obscured environment within a structure. you will be required to demonstrate skills for removing a (conscious) (unconscious) victim from second story window of a structure. Your partner will assist in raising the ladder and will then heal the ladder. You must ascend the ladder and remove the victim to the ground. A safety line will be attached to you in the event of a fall. Once you have properly raised the ladder to the window, I will attach the safety line and you may then ascend the ladder. The victim will be handed out the window to you. You may use whichever technique you deem appropriate to remove the victim.

**PREPARATION & EQUIPMENT**

Full personal protective clothing including SCBA (on air),  
Various size ladders  
Portable radio  
Flashlight  
Hose line  
Various hand tools  
Rescue mannequin



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.9	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 13</b>	<b>Scored points</b>	<b>Scored points</b>
Size up the problem and select the appropriate tool(s) and equipment...2 pts		
Ladders are correctly placed for assignment (if warranted by scenario)...2 pts		
Correctly open all doors (feeling for heat and opening slowly, keeping control of the door) or windows .....1 pts		
Establish, maintain, and search in an effective pattern (i.e. left-hand or right-hand) .....2 pts		
Searching in a body position appropriate for the conditions.....1 pts		
Use hose line effectively (if applicable) .....1 pts		
Find and remove victim using appropriate techniques .....2 pts		
Complete the primary search. ....1 pts		
Maintain team integrity, communication, and safety throughout search...1 pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 12 out of 13 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 14-A**

**Interior Fire Attack- Grade Level**

**PERFORMANCE STANDARD**

Attack a grade level interior structure fire operating as a member of a team, so that team integrity is maintained, access is gained into the fire area, attack techniques facilitate suppression of the fire, hidden fires are located and controlled, hazards are recognized and managed, and the fire is brought under control

**INSTRUCTIONS**

At this station, you will be required to operate as a member of a team, assess and control hazards; and extinguish a class "A" interior structure fire. You will also be required to locate & suppress hidden interior wall & subfloor fires.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (on air)  
Hose line (min. 1 ½")  
Hand tools  
Portable radio  
Flashlight  
Fire/pumper apparatus



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.10	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 14A</b>	Scored points		Scored points	
Properly wear full protective clothing and SCBA (on air) .....P/F				
Properly deploy and charge hose line for fire attack .....1 pts				
Properly bleed hose line, adjust nozzle, and prevent water hammer ...2 pts				
Check door before entering and sound floor for stability .....1 pts				
Stay low upon entry and approaching fire .....1 pts				
Attack and extinguish the fire using an appropriate attack method ...1 pts				
Demonstrate the following attack methods: DIRECT, INDIRECT, COMBINATION .....1 pts				
Overhaul fire scene while protecting and preserving signs of cause or origin (if present) .....1 pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 6 out of 8 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_





**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 14-B**

**Interior Fire Attack- Above Grade**

**PERFORMANCE STANDARD**

Attack an above grade interior structure fire operating as a member of a team, so that team integrity is maintained, the attack line is deployed for advancement, ladders are correctly placed, attack techniques facilitate suppression of the fire, hidden fires are located and controlled, operating as a member of a team, so that team integrity is maintained, the attack line is deployed for advancement

**INSTRUCTIONS**

At this station, you will be required to operate as a member of a team, advancing a charged hose line up a ladder; assess and control hazards; and extinguish a class “A” interior structure fire. You will also be required to locate & suppress hidden interior wall & subfloor fires.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (on air)  
Hose line (min. 1 ½")  
Hand tools  
Portable radio  
Flashlight  
Various size ladders  
Fire/pumper apparatus



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.10 <b>Performance Test # 14 B</b>	<u>TEST</u>		<u>RETEST</u>	
	Scored points		Scored points	
Properly wear full protective clothing and SCBA (on air) .....P/F				
Properly deploy and charge hose line for fire attack .....1 pts				
Properly bleed hose line, adjust nozzle, and prevent water hammer ....2 pts				
Check door before entering and sound floor for stability .....1 pts				
Stay low upon entry and approaching fire .....1 pts				
Attack and extinguish the fire using an appropriate attack method ...1 pts				
Demonstrate the following attack methods: DIRECT, INDIRECT, COMBINATION .....1 pts				
Overhaul fire scene while protecting and preserving signs of cause or origin (if present) .....1 pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 7 out of 8 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 14-C**

**Interior Fire Attack- Below Grade**

**PERFORMANCE STANDARD**

Attack a below grade interior structure fire operating as a member of a team, so that team integrity is maintained, the attack line is deployed for advancement, access is gained into the fire area, attack techniques facilitate suppression of the fire, hidden fires are located and controlled, hazards are recognized and managed, and the fire is brought under control

**INSTRUCTIONS**

At this station, you will be required to operate as a member of a team, advancing a charged hose line down an interior stairway; assess and control hazards; and extinguish a class “A” interior structure fire. You will also be required to locate & suppress hidden interior wall & subfloor fires.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (on air)  
Hose line (min. 1 ½")  
Hand tools  
Portable radio  
Flashlight  
Various size ladders  
Fire/pumper apparatus



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.10 <b>Performance Test # 14C</b>	<u><b>TEST</b></u>		<u><b>RETEST</b></u>	
	<b>Scored points</b>		<b>Scored points</b>	
Properly wear full protective clothing and SCBA (on air).....P/F				
Properly deploy and charge hose line for fire attack .....1 pts				
Properly bleed attack line, adjust nozzle, and prevent water hammer ...2 pts				
Ventilate or call for ventilation above fire (if possible) .....1 pts				
Check door before entering and sound floor for stability .....1 pts				
Descend stairs safely and quickly when ventilation accomplished ...1 pts				
At bottom of stairs search for and correctly extinguish the fire using appropriate attack method .....1 pts				
Demonstrate the following attack methods: DIRECT, INDIRECT, COMBINATION .....1 pts				
Overhaul fire scene while protecting and preserving signs of cause or origin (if present) .....1 pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 7 out of 9 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 14-D**

**Extend or Replace Hose Section**

**PERFORMANCE STANDARD**

Extend or replace a hose line as a member of a team, so that team integrity is maintained, hose sections are added or replaced on a charged line, and all sections of hose are recharged

**INSTRUCTIONS**

At this station, you will be required to operate as a member of a team, assess and control hazards; and extinguish a class “A” interior structure fire. You will also be required to locate & suppress hidden interior wall & subfloor fires. Finally, you will individually extend a hose line and replace a burst section of hose.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA,  
Hose line (min. 1 ½")  
Hand tools  
Portable radio  
Flashlight  
Hose clamp  
Various hose appliance/tools  
Hose clamp (optional)  
Fire/pumper apparatus



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

	<u>TEST</u>		<u>RETEST</u>	
<b>NFPA 1001: 5.3.10</b>	<b>Scored points</b>		<b>Scored points</b>	
<b>Performance Test # 14D</b>				
<b>EXTEND A SECTION OF FIRE HOSE</b>				
Properly wear full protective clothing and SCBA (off air) .....P/F				
Select hose section to be added to line and place it in position .....1 pts				
Correctly shut down water flow at nearest appliance or source; <i>or</i> , Correctly apply hose clamp .....2 pts				
Bleed pressure and undo coupling or remove nozzle .....1 pts				
Extend hose length by at least one section, tighten couplings, and replace nozzle (if applicable) .....1 pts				
Ensure nozzle is closed and is secure .....1 pts				
Correctly restore water flow at nearest appliance or source; <i>or</i> , slowly open hose clamp to avoid water hammer .....2 pts				
Verify pressure at the nozzle and that all connections are tightened... 1 pts				
<b>REPLACE A SECTION OF FIRE HOSE</b>				
Properly wear full protective clothing and SCBA (off air) .....P/F				
Stage replacement hose section near damaged hose section .....1 pts				
Correctly shut down water flow at nearest appliance or source; <i>or</i> , Correctly apply hose clamp .....2 pts				
Bleed pressure, undo couplings, and remove damaged hose .....1 pts				
Replace damaged hose section and tighten coupling .....1 pts				
Ensure nozzle is closed and is secure .....1 pts				
Correctly restore water flow at nearest appliance or source, <i>or</i> , Slowly open hose clamp to avoid water hammer .....2 pts				
Verify pressure at the nozzle and that all connections are tightened... 1 pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Required to pass:**

Candidate must receive a mandatory score of 16 out of 18 points for passing.

**Proctor Comments:**

---

---

---

---

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 15**

**Horizontal Ventilation**

**PERFORMANCE STANDARD**

Perform horizontal ventilation on a structure operating as part of a team, so that the ventilation openings are free of obstructions, tools are used as designed, ladders are correctly placed, ventilation devices are correctly placed, and the structure is cleared of smoke

**INSTRUCTIONS**

At this station, you will be required to perform horizontal ventilation on a smoke-filled structure while operating as a member of a team. You will ventilate the structure using (positive pressure) (hydraulic) ventilation. You will select the proper tools, break glass using approved techniques, and completely clear the window area of sharp edges. You will be required to wear the full Personal Protective Clothing ensemble, to include eye protection, if you perform the task from the exterior of the simulated structure. If you perform the task from the interior of the structure, you must wear the full Personal Protective Clothing ensemble and SCBA. After all glass is cleared, you will place and activate ventilation devices (if applicable) and clear smoke from structure.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (on air as determined by Certifying Officer)  
Hose line  
Hand tools  
Pike pole  
Ladder  
Positive pressure fan  
Smoke ejector





**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.3.11	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 15</b>	<b>Scored points</b>	<b>Scored points</b>
<b>BREAK WINDOW OR DOOR GLASS FOR VENTILATION</b>		
Appropriately place ladder (if needed) .....P/F		
Choose proper tool for task and carry tool safely .....2 pts		
Assume proper position .....1 pts		
Break glass and remove any remaining obstructions from opening .....1 pts		
<b>FORCED VENTILATION- Certifying Officer shall select one of the following ventilation techniques for final certification examination :</b>		
<b>Positive</b>		
Properly place fan in front of adequate entry point .....1 pts		
Ensure exit point is no larger than entrance opening, or in accordance with fan manufacturer’s recommendation .....2 pts		
Start fan, open entry point (block open if necessary) and ensure that the cone of air covers entire opening .....1 pts		
<b>Negative</b>		
Remove objects that might be drawn into fan ( <i>curtains, drapes, etc.</i> ) .....1 pts		
Properly place fan in exhaust opening by hanging from window or door casing, door edge (with door blocked open), or from leaning ladder over opening ...1 pts		
Create an entrance opening preferably on upwind side of building .....1 pts		
Start fan and prevent churning by covering the area around fan with salvage covers or other material .....2pts		
<b>Hydraulic</b>		
Remove objects that might be drawn into fan ( <i>curtains, drapes, etc.</i> ).....1 pts		
Adjust fog pattern to cover 85-90% of opening .....1 pts		
Place nozzle at least 2 feet back from opening .....1 pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 14 out of 16 points for passing.



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Proctor Comments:**

---

---

---

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 16**

**Vertical Ventilation**

**PERFORMANCE STANDARD**

Perform vertical ventilation on a structure operating as part of a team, so that ladders are correctly positioned, a specified opening is created, all ventilation barriers are removed, structural integrity is not compromised, products of combustion are removed, and the team retreats from the area when ventilation is accomplished

**INSTRUCTIONS**

At this station, you will be required to perform vertical ventilation on a (floor) (flat roof) (pitched roof). While operating as a member of a team, you will select the proper tools and ladders and then safely carry equipment to the ventilation site. You will properly raise a ladder for roof access. You will safely ascend and descend the ground ladder with tools. On the ventilation prop, you must determine the integrity of the roof and identify structural components of the target ventilation area. You will cut an adequately sized ventilation hole and remove all ventilation barriers. The ventilation cut must not compromise the structural integrity of the roof. You will safely exit the area as a team, taking all tools and equipment with you.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (on air when accessing roof)  
Roof prop  
Roof ladder  
Various extension ladders  
Chainsaw/cutting tools  
Pike pole  
Pick head axe



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.12	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 16</b>	<b>Scored points</b>		<b>Scored points</b>	
Properly wear full protective clothing and SCBA (on air) .....2pts				
Collect and organize necessary equipment and tools .....1pts				
Select and properly carry ladders appropriate for roof ventilation .....2pts				
Locate position for opening at highest point on roof above fire ..... 1pts				
Properly place and secure ladder for roof ventilation .....2pts				
Sound roof for integrity and location of roof joists and rafters ..... 1pts				
Correctly carry roof ladder while ascending ground ladder and place in position on roof up-wind from intended ventilation site .....2pts				
Move tools to roof utilizing teamwork (after starting & stopping power tools on ground) .....2pts				
Sound roof for integrity and location of roof joists and rafters .....1pts				
Make an opening at least 4' x 4' in size .....1pts				
Remove appropriate roof materials after cuts have been completed.....1pts				
Push ceiling through .....1pts				
Have team exit roof immediately after performing ventilation .....1pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 16 out of 18 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 17-A**

**Overhaul**

**PERFORMANCE STANDARD**

Overhaul a fire scene, so that structural integrity is not compromised, all hidden fires are discovered, fire cause evidence is preserved, and the fire is extinguished

**INSTRUCTIONS**

At this station, you will be required to demonstrate the overhaul of a fire scene so that all hidden fires are exposed and extinguished. Full Personal Protective Clothing ensemble, including SCBA, must be worn during this evaluation. You are responsible for recognizing and preserving areas of fire origin and/or evidence of arson. Void spaces should be exposed while maintaining structural integrity. Water must be applied for maximum effectiveness and the entire structure should be evaluated for complete extinguishment.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (on air)  
Pike poles  
Hand tools  
Thermal imager (if available)  
Attack line and/or portable water extinguisher



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 17A</b>	<b>Scored points</b>	<b>Scored points</b>
NFPA 1001: 5.3.13		
Properly wear full protective clothing and SCBA (on air) .....2pts		
Deploy attack line .....1pts		
Select proper tools and equipment for overhaul requested .....1pts		
Demonstrate locating hidden fires by sight, touch, sound, or electronic sensor .....2pts		
Expose hidden fires in ceilings, walls, and/or subfloor spaces .....1pts		
Remove or extinguish burning objects .....1pts		
Apply only as much water as necessary for extinguishment .....1pts		
Preserve evidence or signs of cause and origin .....1pts		
Delay thorough salvage or overhaul until cause and origin are determined .....1pts		
Ensure debris piles or burning material is completely extinguished...2pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 11 out of 13 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 17-B**

**Deploy Attack Line**

**PERFORMANCE STANDARD**

Deploy an attack line, so that the appropriate hose line is selected; the hose is correctly deployed; the line is safely charged; kinks are removed; and nozzle pattern is appropriately adjusted for fire attack

**INSTRUCTIONS**

At this station, you will be required to demonstrate the overhaul of a fire scene so that all hidden fires are exposed and extinguished. Full Personal Protective Clothing ensemble, including SCBA, must be worn during this evaluation. Void spaces should be exposed while maintaining structural integrity. Water must be applied for maximum effectiveness and the entire structure should be evaluated for complete extinguishment.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (on air) and an attack line



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.13	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 17B</b>	<b>Scored points</b>	<b>Scored points</b>
Properly wear full protective clothing and SCBA (off air unless combined with fire attack) .....2pts		
Select appropriate pre-connect hose for scenario .....1pts		
Correctly pull hose out of the bed and proceeds towards fire until hose is completely out of the bed .....2pts.		
Remove kinks in hose and correctly prepare for advance flake or orient to play out without significant difficulty ..... 2pts		
Secure nozzle, call or signal for water, bleed air from the attack line and appropriately adjust nozzle pattern for fire attack....1pts		
Close nozzle slowly to prevent water hammer .....1pts		
Shut down line, drain hose, and properly reload hose into bed .....1pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 8 out of 10 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_





**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 18**

**Property Conservation**

**PERFORMANCE STANDARD**

Conserve property as a member of a team, so that the building and its contents are protected from further damage

**INSTRUCTIONS**

At this station, you will be required to conduct salvage operations to conserve property, operating alone and as a member of a team. Full Personal Protective Clothing must be worn during this evaluation. You will deploy covering materials; remove debris; construct water chutes and catchalls; and roll or fold salvage covers as directed. You will be responsible for recognizing and preserving areas of origin and/or evidence or arson as well as closing building openings. At a simulated building with an activated sprinkler system. You will stop the flow of water from an activated sprinkler head. Additionally, you will close a sprinkler system control valve.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA  
Pike poles  
Salvage covers  
Sprinkler wedges or stoppers



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.3.14	<u>TEST</u>		<u>RETEST</u>	
Performance Test # 18	Scored points		Scored points	
<b>COVER PROPERTY</b>				
Arrange furnishing in close piles(s) and raise off the floor if possible ... 1pts				
Select proper salvage cover and deploy covering materials over furnishings using one of the following methods:..... 1pts Deploy a folded salvage cover Deploy a rolled salvage cover				
Construct one of the following to effectively route water from one area to another ..... 1pts				
Demonstrate how to stop the flow of water from a sprinkler using wedges or stoppers ..... 1pts				
Correctly fold and/or roll a salvage cover and return to service ..... 1pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 5 out of 5 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 19**

**Water Supply**

**PERFORMANCE STANDARD**

Connect a pumper apparatus to water supply as a member of a team, so that connections are tight and water flow is unobstructed

**INSTRUCTIONS**

At this station, you will be required to connect a pumper to a water supply. Working by yourself, you will complete the pumper to hydrant connection for both a forward and reverse lay. Additionally, you will make the hydrant to pumper connection using a soft-sleeve intake supply hose. You must operate the hydrant safely and correctly. As a member of a team, you will deploy two (2) portable water tanks and equipment necessary to transfer water between them. You will connect all hose and equipment necessary to draft water from one of the tanks to the pumper. You will not need to actually move water, only to deploy the equipment and establish all connections for the driver/operator to do so.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (as determined by Certifying Officer)  
Hydrant kit  
Appropriate supply line (min. 2 ½ hose line)



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.3.15	<u>TEST</u>	<u>RETEST</u>
Performance Test # 19	Scored points	Scored points
<b>FIRE HYDRANT CONNECTION VIA FORWARD &amp; REVERSE LAY</b>		
Connect supply hose to hydrant .....2pts		
Connect supply hose to pumper intake .....1pts		
Remove kinks from hose .....1pts		
Fully open hydrant .....1pts		
At end of operation, fully close the hydrant.....1pts		
Place all equipment and hydrant in a ready condition .....1pts		
<b>STATIC WATER SOURCE</b>		
Deploy portable water tank .....2pts		
Check gaskets on the hard suction hose for dirt, gravel or defects ...1pts		
Connect strainer <i>or</i> foot <i>or</i> float to hose .....1pts		
Fasten rope/strap to strainer to aid in handling the hose .....1pts		
Connect hard suction hose to pumper .....1pts		
Use rubber mallet to ensure air tight connections .....1pts		
Lower hose and strainer into static water source .....1pts		
Signal pumper operator to start drafting procedure .....2pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 15 out of 17 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 20-A**

**Fire Extinguisher- Class A**

**PERFORMANCE STANDARD**

Extinguish an incipient Class A fire, so that the correct extinguisher is chosen, the fire is completely extinguished, and correct extinguisher-handling techniques are followed

**INSTRUCTIONS**

At this station, you will be required to completely extinguish an incipient Class “A” fire. You will be responsible for selecting the correct portable extinguisher for the type and size of fire. Once you have chosen the correct extinguisher, you are responsible for activating the extinguisher, testing operation by a brief discharge of agent, approaching the fire correctly, and using proper portable extinguisher handling techniques to completely extinguish the fire.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (as determined by Certifying Officer)  
Various fire extinguishers (class A, B, C)  
Burn pan



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.3.16	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 20A</b>	Scored points		Scored points	
Correctly identify the class of fire .....2pts				
Select an appropriate extinguisher based on the type and size of fire...2pts				
Properly activate the extinguisher (pulls pin and/or punctures cartridge)...2pts				
Test operation of the extinguisher by a brief discharge of agent before approaching the fire .....2pts				
Safely carry the extinguisher and approach the fire from upwind ..... 1pts				
Approach to an effective distance for discharge of the selected extinguisher .....1pts				
Discharge extinguishing agent on the base of the fire and sweep over the fire area .....2pts				
Advance on the remaining burning material while continuing to extinguish hot spots ..... 1pts				
Extinguish the fire and check for remaining hot spots .....1pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 12 out of 14 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 20-B**

**Fire Extinguisher- Class B**

**PERFORMANCE STANDARD**

Extinguish an incipient Class B fire, so that the correct extinguisher is chosen, the fire is completely extinguished, and correct extinguisher-handling techniques are followed

**INSTRUCTIONS**

At this station, you will be required to completely extinguish an incipient Class “B” fire. You will be responsible for selecting the correct portable extinguisher for the type and size of fire. Once you have chosen the correct extinguisher, you are responsible for activating the extinguisher, testing operation by a brief discharge of agent, approaching the fire correctly, and using proper portable extinguisher handling techniques to completely extinguish the fire.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (as determined by Certifying Officer)  
Various fire extinguishers (class A, B, C)  
Burn pan



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.3.16	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 20B</b>	<b>Scored points</b>	<b>Scored points</b>
Correctly identify the class of fire .....2pts		
Select an appropriate extinguisher based on the type and size of fire ...2pts		
Properly activate the extinguisher (pulls pin and/or punctures cartridge) .....2pts		
Test operation of the extinguisher by a brief discharge of agent before approaching the fire .....2pts		
Safely carry the extinguisher and approach the fire from upwind ....1pts		
Approach to an effective distance for discharge of the selected extinguisher .....1pts		
Discharge extinguishing agent on the base of the fire and sweep over the fire area .....2pts		
Advance on the burning material and continue to extinguish the burning liquid .....1pts		
Extinguish the fire and watch for re-flash of flammable liquids .....1pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 12 out of 14 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_





**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 20-C**

**Fire Extinguisher- Class C**

**PERFORMANCE STANDARD**

Extinguish an incipient Class C fire, so that the correct extinguisher is chosen, the fire is completely extinguished, and correct extinguisher-handling techniques are followed

**INSTRUCTIONS**

At this station, you will be required to completely extinguish an incipient Class “C” fire. You will be responsible for selecting the correct portable extinguisher for the type and size of fire. Once you have chosen the correct extinguisher, you are responsible for activating the extinguisher, testing operation by a brief discharge of agent, approaching the fire correctly, and using proper portable extinguisher handling techniques to completely extinguish the fire.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (as determined by Certifying Officer)  
Various fire extinguishers (class A, B, C)  
Burn pan



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.3.16 <b>Performance Test # 20C</b>	<u>TEST</u>		<u>RETEST</u>	
	Scored points		Scored points	
Correctly identify the class of fire .....2pts				
Attempt to de-energize the item on fire .....2pts				
Select an appropriate extinguisher based on the type and size of fire ...2pts				
Properly activate the extinguisher (pulls pin and/or punctures cartridge) .....2pts				
Test operation of the extinguisher by a brief discharge of agent before approaching the fire .....2pts				
Safely carry the extinguisher and approach the fire from upwind ....1pts				
Approach to an effective distance for discharge of the selected extinguisher .....1pts				
Discharge extinguishing agent on the base of the fire and sweep over the fire area .....2pts				
Advance on the remaining burning material while continuing to extinguish hot spots .....1pts				
Extinguish the fire and check for remaining hotspots .....1pts				
Verify the item involved in the fire is de-energized .....1pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 15 out of 17 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 21**

**Illuminate Emergency Scene**

**PERFORMANCE STANDARD**

Illuminate an emergency scene, so that designated areas are illuminated and all equipment is operated within the manufacturer's listed safety precaution

**INSTRUCTIONS**

At this station, you will be required to illuminate a simulated emergency scene. You are responsible for checking the fuel and oil in the power plant prior to starting the power plant, starting the power plant, and arranging extension cords to minimize trip hazards. You must also deploy portable lights to maximize their effectiveness over the designated area, follow all manufacturer's listed safety precautions for the generator you are using, reset ground fault interrupter devices if necessary, and properly de-energize all equipment properly when I direct you to do so.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (as determined by Certifying Officer)  
Portable or mounted power supply  
Lights  
Cords  
Connectors and ground fault interrupters  
Extra fuel and oil



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.3.17	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 21</b>	<b>Scored points</b>	<b>Scored points</b>
Lift equipment safely .....P/F		
Locate power plant in a remote and well vented location ..... 1pts		
Arrange power cords neatly to minimize trip hazards ..... 1pts		
Organize lights in a useful position to illuminate the area sufficiently... 1pts		
Start power plant ..... 1pts		
Plug cords into power unit or junction box and furnish illumination... 1pts		
Shut down equipment when told to do so ..... 1pts		
Allow equipment to cool before returning to service or verbally explain the need to do so ..... 1pts		
Clean equipment, check oil, and refuel power plant or verbally explain the need to do so ..... 1pts		
Lift equipment safely ..... 1pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail
	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 7 out of 9 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 22**

**Building Utilities**

**PERFORMANCE STANDARD**

Turn off building utilities, so that the assignment is safely completed

**INSTRUCTIONS**

At this station, you will be required to turn off building utilities, including electricity, water, and gas utilities for the building. You must use appropriate tools and safety precautions when performing each task. You must tell me of any (simulated) hazards associated with each utility that concern you upon securing each utility and what you would do in each case.

**PREPARATION & EQUIPMENT**

Full personal protective equipment with SCBA (as determined by Certifying Officer)  
Hand tools for controlling utilities  
Utility service boxes



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.3.18	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 22</b>	Scored points		Scored points	
Locate Electrical main panel and move switch or breaker to "off" position .....1pts				
Locate natural gas meter and rotate gas shutoff valve to closed position .....1pts				
Locate LPG/CNG storage tank/cylinder and turn valve clockwise to shut off .....1pts				
Locate water meter box and correctly turn or rotate valve to stop the flow of water .....1pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 3 out of 4 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 23**

**Combat Ground Cover Fire**

**PERFORMANCE STANDARD**

Combat a ground cover fire operating as a member of a team, so that threats to property are reported, threats to personal safety are recognized, retreat is quickly accomplished when warranted, and the assignment is completed.

**INSTRUCTIONS**

At this station, you will be given a simulated ground cover fire scenario. I will provide to you those key points that will assist you in verbalizing techniques to combat the ground cover fire. You will verbalize to me any exposure threats, how you would protect those exposures. You will describe to me the construction of a fire line and the steps necessary to maintain it. You must recognize any threats to personnel safety and explain when a retreat should be called for. You will then verbalize and demonstrate how you would extinguish a ground cover fire using this (pumper) (grass truck).

**PREPARATION & EQUIPMENT**

Wildland personal protective equipment  
Wildland hand tools  
Wildland hose lines  
Pump extinguishers, and a map or drawing



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

	<u>TEST</u>	<u>RETEST</u>
	Scored points	Scored points
NFPA 1001: 5.3.19		
<b>Performance Test # 23</b>		
Don or describe what personal protective clothing should be worn and what tools and equipment are needed ( <i>If no respiratory hazards SCBA and hood not required, wild land protective clothing recommended if available</i> )...2pts		
Perform an assessment of the incident with respect to type of fuel, topography, weather conditions, and exposures ..... 1pts		
Explain the exposures present and what protection is needed, or conduct the operation ..... 1pts		
Based on available fuels and terrain, conduct or explain construction and maintenance of a fire line using hand tools ..... 1pts		
Conduct or explain extinguishment of ground cover fires using hand tools and a backpack or vest pump extinguisher ..... 1pts		
Conduct or explain extinguishment of ground cover fires using hand tools and a wildland hand line ..... 1pts		
Identify the need for lookouts, communications, safety zones, and escape routes ..... 2pts		
Explain how to quickly retreat using established escape routes ..... 2pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail
	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 9 out of 11 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_





**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 24-A**

**Maintenance: Ladders**

**PERFORMANCE STANDARD**

Clean and check ladders, so that equipment is clean and maintained according to manufacturer or departmental guidelines, maintenance is recorded, and equipment is placed in a ready state or reported otherwise

**INSTRUCTIONS**

At this station, you will be required to clean and check various pieces of equipment. You have all the necessary cleaning supplies with which to accomplish your task. You must verbalize to me all the components that you are checking so that you may receive complete credit.

**PREPARATION & EQUIPMENT**

Ladders  
Service tags  
Cleaning supplies  
Maintenance log book/record



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 24A</b>	Scored points		Scored points	
Washes and dries per manufacturer's specification ..... 1pts				
Inspects halyard/cable ..... 1pts				
Inspects all movable parts of ladder (i.e. guide, pulley(s), locks, and beams/rails) ..... 1pts				
Examine all, rungs, bolts, rivets, welds, and heat indicator ..... 1pts				
Check lubrication of moveable parts and lubricate if necessary ... 1pts				
If defects found, mark defects in accordance with manufacturer or department guidelines and place equipment out of service ..... 1pts				
Verbalizes conditions that cannot be corrected through cleaning or maintenance ..... 1pts				
If no defects found, place equipment in ready state ..... 1pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 7 out of 8 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 24-B**

**Maintenance: SCBA**

**PERFORMANCE STANDARD**

Clean and check SCBA's, so that equipment is clean and maintained according to manufacturer or departmental guidelines, maintenance is recorded, and equipment is placed in a ready state or reported otherwise

**INSTRUCTIONS**

At this station, you will be required to clean and check various pieces of equipment. You have all the necessary cleaning supplies with which to accomplish your task. You must verbalize to me all the components that you are checking so that you may receive complete credit.

**PREPARATION & EQUIPMENT**

SCBA ensemble  
Service tags  
Cleaning supplies  
Maintenance log book/record



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.5.1	<u>TEST</u>	<u>RETEST</u>
Performance Test # 24B	Scored points	Scored points
Wash face piece, hoses, and exhalation valve with department's cleaner/disinfectant and rinse completely with water and air dry.....1pts		
Clean SCBA with damp cloth or according to department policies .....1pts		
Check straps and backpack assembly .....1pts		
Check condition and hydrostatic test date of cylinder .....1pts		
Turn the cylinder valve on fully .....1pts		
Compare that two pressure gauges are within 100 psi (low pressure) within 200 psi (high pressure) of each other .....1pts		
Check regulator operation by connecting to face piece and breathing...1pts		
Check face piece and exhalation valve by inhaling & exhaling .....1pts		
Check by-pass operation and ensure by-pass is in the off position after testing .....1pts		
Check low pressure alarm while bleeding the air line.....1pts		
Return all straps, valves, and components back to ready state .....1pts		
Check the air cylinder is in off position and for adequate air pressure (90% - full) .....1pts		
Candidate will remove from service and notify supervisor if any irregularities are found .....1pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail
	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 12 out of 13 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 24-C**

**Maintenance: Ropes**

**PERFORMANCE STANDARD**

Clean and check ropes, so that equipment is clean and maintained according to manufacturer or departmental guidelines, maintenance is recorded, and equipment is placed in a ready state or reported otherwise

**INSTRUCTIONS**

At this station, you will be required to clean and check various pieces of equipment. You have all the necessary cleaning supplies with which to accomplish your task. You must verbalize to me all the components that you are checking so that you may receive complete credit.

**PREPARATION & EQUIPMENT**

Ropes  
Service tags  
Cleaning supplies  
Maintenance log book/record.



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

**Candidate:** \_\_\_\_\_ **Notes:** \_\_\_\_\_

**Training Provider:** \_\_\_\_\_

**Test Site:** \_\_\_\_\_

**Examiner:** \_\_\_\_\_

NFPA 1001: 5.5.1	<u>TEST</u>		<u>RETEST</u>	
<b>Performance Test # 24C</b>	<b>Scored points</b>		<b>Scored points</b>	
Examine the entire surface of the rope for cuts, abrasions, stains, odor, or fraying .....1pts				
Examine the inner component by twisting the rope or feeling for bunching and thinness .....1pts				
Clean rope using clear water .....1pts				
Allow rope to dry completely, or state rope must be allowed to dry completely .....1pts				
Perform additional inspection after drying .....1pts				
If damage found, mark defects in accordance with manufacturer or department guidelines and place equipment out of service .....1pts				
If no damage found, properly store rope using coil method or rope bag storage .....2pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 6 out of 8 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test Proctor (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_

**Re-Test candidate (Print & Sign):** \_\_\_\_\_ **Date** \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 24-D**

**Maintenance: Ventilation Equipment & Hand Tools**

**PERFORMANCE STANDARD**

Clean and inspect ventilation equipment and hand tools, so that equipment and tools are clean and maintained according to manufacturer or departmental guidelines, maintenance is recorded, and equipment is placed in a ready state or reported otherwise

**INSTRUCTIONS**

At this station, you will be required to clean and check various pieces of equipment. You have all the necessary cleaning supplies with which to accomplish your task. You must verbalize to me all the components that you are checking so that you may receive complete credit.

**PREPARATION & EQUIPMENT**

Ventilation equipment  
Hand tools  
Service tags  
Cleaning supplies  
Maintenance log book/record



# Arab Fire Safety and Security Academy (AFSSAC)

## FIRE FIGHTER I

### PERFORMANCE STANDARDS

### NFPA 1001, 2013 Edition

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

	<u>TEST</u>	<u>RETEST</u>
Performance Test # 24D	Scored points	Scored points
<b>VENTILATION EQUIPMENT</b>		
Check blades for sharpness and equipment for completeness and readiness .....1pts		
Check that appropriate guards are in place and secure .....1pts		
Start equipment and ensure proper operation .....1pts		
For electric fans, check cords for cuts and frays .....1pts		
<b>Wooden Handles</b>		
Check for cracks, blister, or splinters .....1pts		
Sand wooden handles if needed .....1pts		
Clean with soapy water, rinse, and dry after use .....1pts		
Apply coat of boiled linseed oil to the handle .....1pts		
Check to ensure head is on tight .....1pts		
<b>Fiberglas Handles</b>		
Wash with warm, soapy water .....1pts		
Dry with soft, dry cloth .....1pts		
Check to ensure head is on tight .....1pts		
<b>Cutting Edges:</b>		
Check to ensure cutting edge is free of nicks or tears .....1pts		
File the edges by hand .....1pts		
<b>Plated Surfaces:</b>		
Inspect for damage .....1pts		
Wipe plated surface clean or wash with soap and water .....1pts		
<b>Unprotected Metal Surfaces:</b>		
Keep clean of rust .....1pts		
Keep oiled when not in use (Light machine oil or similar product) .....1pts		
Check to ensure no paint is on surface (may hide cracks) .....1pts		
Check that metal surfaces are free of burred or sharp edges (file as necessary) .....1pts		
<b>REPORT DAMAGE:</b>		
If damage found to any of the above, mark defects in accordance with manufacturer or department guidelines and place equipment out of service .....2pts		
If no damage found, properly store tools/equipment in a ready state .....1pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail
	<input type="checkbox"/> pass	<input type="checkbox"/> fail





**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Required to pass:**

Candidate must receive a mandatory score of 21 out of 23 points for passing.

**Proctor Comments:**

---

---

---

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 24-E**

**Maintenance: Salvage Equipment**

**PERFORMANCE STANDARD**

Clean and inspect salvage equipment, so that equipment is clean and maintained according to manufacturer or departmental guidelines, maintenance is recorded, and equipment is placed in a ready state or reported otherwise

**INSTRUCTIONS**

At this station, you will be required to clean and check various pieces of equipment. You have all the necessary cleaning supplies with which to accomplish your task. You must verbalize to me all the components that you are checking so that you may receive complete credit.

**PREPARATION & EQUIPMENT**

Salvage covers  
Service tags  
Cleaning supplies  
Maintenance log book/record



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.5.1	<u>TEST</u>	<u>RETEST</u>
<b>Performance Test # 24E</b>	<b>Scored points</b>	<b>Scored points</b>
Spread the salvage cover out flat for cleaning .....1pts		
Scrub the cover with detergent solution and a brush .....1pts		
Rinse cover thoroughly .....1pts		
State cover should be thoroughly dried before returning to service ... 1pts		
Check the cover thoroughly for damage by having assistants hold the cover above heads while looking for holes and tears .....1pts		
If damage found to any of the above, mark defects in accordance with manufacturer or department guidelines and place equipment out of service in accordance with department policy and procedures.....2pts		
If no damage found, properly store equipment in a ready state .....1pts		
<b>Total Score</b>		
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 6 out of 8 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 25**

**Maintenance: Fire Hose**

**PERFORMANCE STANDARD**

Clean, inspect, and return fire hose to service, so that damage is noted and corrected, equipment is placed in a ready state or reported otherwise, and service maintenance is recorded

**INSTRUCTIONS**

At this station, you will be required to inspect, clean, and return fire hose to service, including rolling and reloading the hose. You are responsible for examining all components and movable parts for damage or conditions which would render the equipment dangerous or unusable. You will verbalize to me any such damage that you should find. You have all the necessary cleaning supplies with which to accomplish your task.

**PREPARATION & EQUIPMENT**

Personal protective clothing (Certifying Officer to determine what PPE shall be worn)  
Scrub brush  
Hose  
Cleaning supplies  
Replacement gaskets  
Hose washer and dryer (if available)  
Tags  
Maintenance log book/record



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.5.2	<u>TEST</u>		<u>RETEST</u>	
Performance Test # 25	Scored points		Scored points	
<b>CLEANING AND INSPECTION</b>				
Clean hose using water and scrub brush (mild detergent may be used) ... 1pts				
Clean couplings by removing gaskets, wash with warm soapy water and reinstalling gaskets (replacing if defective) .....1pts				
Dry hose ..... 1pts				
Inspect hose for signs of mechanical damage .....1pts				
Inspect hose for dirt and debris .....1pts				
Inspect hose for loose couplings ..... 1pts				
Inspect hose for damaged male or female threads .....1pts				
Inspect and verify that swivel operates freely .....1pts				
If hose is damaged, mark defects in accordance with manufacturer or department guidelines and place hose out of service .....2pts				
If no damage found, properly store or load hose in a ready state .....1pts				
<b>RETURN HOSE TO SERVICE</b>				
Reconnect hose load .....1pts				
Supply hose load .....1pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 12 out of 13 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

---

**Performance Test # 26**

**ACTIVATE AN EMERGENCY CALL FOR ASSISTANCE**

**PERFORMANCE STANDARD**

The ability to initiate an emergency call for assistance in accordance with the AHJ's procedures

**INSTRUCTIONS**

While operating at a simulated fire scene, you shall activate an emergency call for assistance using the department SOP's so that the firefighter can be located and rescued with necessary resources.

**PREPARATION & EQUIPMENT**

Given vision-obscured conditions  
Full PPE



**Arab Fire Safety and Security Academy (AFSSAC)**  
**FIRE FIGHTER I**  
**PERFORMANCE STANDARDS**  
**NFPA 1001, 2013 Edition**

Candidate: \_\_\_\_\_ Notes: \_\_\_\_\_

Training Provider: \_\_\_\_\_

Test Site: \_\_\_\_\_

Examiner: \_\_\_\_\_

NFPA 1001: 5.2.4 Performance Test # 26	<b>TEST</b>		<b>RETEST</b>	
	Scored points		Scored points	
<b>CLEANING AND INSPECTION</b>				
Determine the need to declare a MAYDAY ..... 2 pts				
Announce “MAYDAY, MAYDAY, MAYDAY” over the emergency communications channel ..... 2 pts				
Provide command your information per local SOP’s LUNARS..... 2 pts				
Activate PASS device and press radio emergency button..... 1 pts				
If able, move to a wall and position yourself according to local SOP’s ..... 2 pts				
Activate flashlight and point towards the ceiling ..... 2 pts				
Use tool or object to make noise; remain calm and conserve air; stay in contact with command ..... 1 pts				
<b>Total Score</b>				
<b>RESULT</b>	<input type="checkbox"/> pass	<input type="checkbox"/> fail	<input type="checkbox"/> pass	<input type="checkbox"/> fail

**Required to pass:**

Candidate must receive a mandatory score of 10 out of 12 points for passing.

**Proctor Comments:**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test Proctor (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_

Re-Test candidate (Print & Sign): \_\_\_\_\_ Date \_\_\_\_\_